
Overhead Electricity Lines

DM 14.3 Proposals for overhead electricity lines will be acceptable where it has been demonstrated all the following criteria are met:

- (a) They avoid areas identified for their landscape importance **as set out in SP 8, except where it is demonstrated to the satisfaction of the Council that this is not feasible;**
- (b) They have no unacceptable impact on residential amenity or other sensitive receptors;
- (c) Wirescape within or close to urban areas is kept to a minimum with preference being given to undergrounding services where appropriate; and
- (d) They comply with the ICNIRP guidelines for public exposure to electromagnetic fields.